



**BUREAU
VERITAS**

ATTESTATION of conformity with European Directives

BV LCIE CHINA Number N° 2366AS10CKKS52017
Product Grid-connected PV inverter
Reference BDH-800,BDH-600
Issued to Suzhou Northern Electric Power Technology Co.,Ltd.
Address Kangzhen Building, No. 18, Louyang Road, Suzhou Industrial Park
Manufacturer Suzhou Northern Electric Power Technology Co.,Ltd.
Technical characteristics See below table

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:
LVD Directive 2014/35/EU

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
IEC 62109-1:2010, EN 62109-1:2010	CKKS-ESH-P23051410-1	2023-09-22
IEC 62109-2:2011, EN 62109-2:2011	CKKS-ESH-P23051410-2	

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product

The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), Nov 1st, 2023



Robin Wu
Product Line Manager

This document shall not be reproduced, except in full, without the written approval of BV LCIE China. Information given in this document, are related to the tested specimen of the described electrical sample.



**BUREAU
VERITAS**

Ratings :	BDH-800	BDH-600
MPP DC voltage range [V] :	22-55	
Max. Input DC voltage [V] :	60	
Max. Input DC current [A] :	17*2	14*2
Output AC voltage [V] :	230	
Max. Output AC current [A] :	3,48	2,60
Rated output power [VA] :	800	600

This document shall not be reproduced, except in full, without the written approval of BV LCIE China. Information given in this document, are related to the tested specimen of the described electrical sample.

Version: 8.0 / Nov.24, 2022

Page 2 of

2